


FACT FILE 004

RADIANT BOILER WIRING-ACL 711 TIME SWITCH

N L 1 2 3 4
ACL LP 711 TIME SWITCH



WARNING: Terminals 1 & 3 **Must** be NON Voltage

The introduction of mains voltage to Radiant terminals OR & TA will result in irreparable damage to the main PCB

Wiring Details for ACL LP 711
To
RADIANT RSF 24 BOILER


RADIANT TECHNICAL HELP LINE (UK) 01329 828555

3 AMP FUSED
MAINS SUPPLY



RADIANT BOILER
TERMINAL STRIP

Remember
to remove link from
OR & TA if boiler is **NOT**
fitted with timer



FACTFILE 004

Please Note: These Drawings and notes are purely to assist service engineers, the drawings are not to scale just diagrammatic E&OE © 2001